



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Poland Community School
1250 Maine Street
Poland, ME 04274

Date Printed: 06/28/2022
Work Order #: 2205-01600
Client Job #: 361
Date Received: 05/10/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 06/28/2022
CLIENT NAME: Poland Community School

CLIENT ADDRESS: 1250 Maine Street
 Poland, ME 04274

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 05/10/2022 03:25PM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 22° CELSIUS
CLIENT JOB #: 361

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2205-01600-001	Girl's Locker room sink	I	OT	05/07/2022 10:06AM	<1	ppb			DR-NH	06/24/2022 12:12AM
2205-01600-002	Girl's Locker room shower 1	I	OT	05/07/2022 10:06AM	4.3	ppb			DR-NH	06/24/2022 12:15AM
2205-01600-003	Girl's Locker room shower 2	I	OT	05/07/2022 10:06AM	10.7	ppb			DR-NH	06/24/2022 12:18AM
2205-01600-004	Girl's Locker room shower 3	I	OT	05/07/2022 10:06AM	5.9	ppb			DR-NH	06/24/2022 12:29AM
2205-01600-005	Girl's Locker room shower 4	I	OT	05/07/2022 10:06AM	9.5	ppb			DR-NH	06/24/2022 12:32AM
2205-01600-006	Girl's Locker room shower 5	I	OT	05/07/2022 10:06AM	10.7	ppb			DR-NH	06/24/2022 12:35AM
2205-01600-007	Boy's Locker room sink	I	OT	05/07/2022 10:11AM	<1	ppb			DR-NH	06/24/2022 12:38AM
2205-01600-008	Boy's Locker room shower 1	I	OT	05/07/2022 10:11AM	10.7	ppb			DR-NH	06/24/2022 12:41AM
2205-01600-009	Boy's Locker room shower 2	I	OT	05/07/2022 10:11AM	11.7	ppb			DR-NH	06/24/2022 12:44AM
2205-01600-010	Boy's Locker room shower 3	I	OT	05/07/2022 10:11AM	8.7	ppb			DR-NH	06/24/2022 12:53AM
2205-01600-011	Boy's Locker room shower 4	I	OT	05/07/2022 10:11AM	8.7	ppb			DR-NH	06/24/2022 12:56AM
2205-01600-012	Boy's Locker room shower 5	I	OT	05/07/2022 10:11AM	11.7	ppb			DR-NH	06/24/2022 01:05AM
2205-01600-013	Boy's Locker room shower 6	I	OT	05/07/2022 10:11AM	7.5	ppb			DR-NH	06/24/2022 01:07AM
2205-01600-014	Boy's Locker room shower 7	I	OT	05/07/2022 10:11AM	9.8	ppb			DR-NH	06/24/2022 01:10AM
2205-01600-015	Boy's Locker room shower 8	I	OT	05/07/2022 10:11AM	7.8	ppb			DR-NH	06/24/2022 01:13AM
2205-01600-016	Gym water fountain 1 (left)	I	DWF	05/07/2022 10:14AM	<1	ppb			DR-NH	06/24/2022 01:16AM

Rebecca L. Labranche
 Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 06/28/2022
CLIENT NAME: Poland Community School

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

CLIENT ADDRESS: 1250 Maine Street
 Poland, ME 04274

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 05/10/2022 03:25PM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 22° CELSIUS
CLIENT JOB #: 361

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2205-01600-017	Gym water fountain 2 (right)	I	DWF	05/07/2022 10:14AM	<1	ppb			DR-NH	06/24/2022 01:19AM
2205-01600-018	Kitchen Sprayer	I	KF	05/07/2022 10:22AM	15.4	ppb			DR-NH	06/24/2022 01:22AM
2205-01600-019	Kitchen Dish Sink 1	I	KF	05/07/2022 10:22AM	<1	ppb			DR-NH	06/24/2022 01:25AM
2205-01600-020	Kitchen Dish Sink 2	I	KF	05/07/2022 10:22AM	<1	ppb			DR-NH	06/24/2022 04:55PM
2205-01600-021	Kitchen Pot faucet at stove	I	KF	05/07/2022 10:22AM	44.3	ppb			DR-NH	06/24/2022 04:58PM
2205-01600-022	Kitchen Hand sink	I	KF	05/07/2022 10:22AM	2.2	ppb			DR-NH	06/24/2022 05:01PM
2205-01600-023	Kitchen bathroom sink	I	KF	05/07/2022 10:22AM	1.2	ppb			DR-NH	06/24/2022 05:04PM
2205-01600-024	Kitchen wash sink 1	I	KF	05/07/2022 10:22AM	5.8	ppb			DR-NH	06/24/2022 05:07PM
2205-01600-025	Kitchen wash sink 2	I	KF	05/07/2022 10:22AM	2.9	ppb			DR-NH	06/24/2022 05:10PM
2205-01600-026	Teacher's room sink 1	I	OT	05/07/2022 10:25AM	<1	ppb			DR-NH	06/24/2022 05:13PM
2205-01600-027	Teacher's room sink 2	I	OT	05/07/2022 10:25AM	1.1	ppb			DR-NH	06/24/2022 05:16PM
2205-01600-028	Nurse sink 1	I	OT	05/07/2022 10:16AM	<1	ppb			DR-NH	06/24/2022 05:19PM
2205-01600-029	Nurse sink 2	I	OT	05/07/2022 10:16AM	<1	ppb			DR-NH	06/24/2022 05:22PM
2205-01600-030	Custodian Sink	I	OT	05/07/2022 10:26AM	1.3	ppb			DR-NH	06/24/2022 05:36PM
2205-01600-031	Adult bathroom sink	I	OT	05/07/2022 10:28AM	<1	ppb			DR-NH	06/24/2022 05:39PM
2205-01600-032	Lit Lab sink	I	OT	05/07/2022 10:28AM	1.4	ppb			DR-NH	06/24/2022 05:42PM
2205-01600-033	Girl's room sink (bottom of staires)	I	OT	05/07/2022 10:30AM	2.3	ppb			DR-NH	06/24/2022 05:45PM
2205-01600-034	Boy's room sink (bottom of staires)	I	OT	05/07/2022 10:30AM	1.3	ppb			DR-NH	06/24/2022 05:48PM
2205-01600-035	Room 137 sink	I	OT	05/07/2022 11:51AM	<1	ppb			DR-NH	06/24/2022 05:51PM
2205-01600-036	Room 148 sink	I	OT	05/07/2022 11:52AM	5.8	ppb			DR-NH	06/24/2022 05:54PM
2205-01600-037	Art room sink 1	I	OT	05/07/2022 11:55AM	<1	ppb			DR-NH	06/24/2022 05:57PM
2205-01600-038	Art room sink 2	I	OT	05/07/2022 11:55AM	<1	ppb			DR-NH	06/24/2022 06:09PM
2205-01600-039	Room 172 sink	I	OT	05/07/2022 11:56AM	<1	ppb			DR-NH	06/24/2022 06:12PM
2205-01600-040	Room 173 sink	I	OT	05/07/2022 11:57AM	<1	ppb			DR-NH	06/24/2022 06:20PM

Rebecca L. Labranche
 Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 06/28/2022
CLIENT NAME: Poland Community School

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

CLIENT ADDRESS: 1250 Maine Street
 Poland, ME 04274

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 05/10/2022 03:25PM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 22° CELSIUS
CLIENT JOB #: 361

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2205-01600-041	Water fountain by room 180	I	DWF	05/07/2022 11:58AM	<1	ppb			DR-NH	06/24/2022 06:23PM
2205-01600-042	Room 179 sink	I	OT	05/07/2022 11:59AM	5.0	ppb			DR-NH	06/24/2022 06:26PM
2205-01600-043	Girl's bathroom sink 1 (by boiler rm)	I	OT	05/07/2022 12:00PM	1.1	ppb			DR-NH	06/24/2022 06:29PM
2205-01600-044	Girl's bathroom sink 2 (by boiler rm)	I	OT	05/07/2022 12:00PM	<1	ppb			DR-NH	06/24/2022 06:32PM
2205-01600-045	Girl's bathroom sink 3 (by boiler rm)	I	OT	05/07/2022 12:00PM	<1	ppb			DR-NH	06/24/2022 06:35PM
2205-01600-046	Adult bathroom sink 1 (by boiler rm)	I	OT	05/07/2022 12:01PM	7.2	ppb			DR-NH	06/24/2022 06:44PM
2205-01600-047	Boy's bathroom sink 1 (by boiler rm)	I	OT	05/07/2022 12:02PM	<1	ppb			DR-NH	06/24/2022 06:47PM
2205-01600-048	Boy's bathroom sink 2 (by boiler rm)	I	OT	05/07/2022 12:02PM	<1	ppb			DR-NH	06/24/2022 06:50PM
2205-01600-049	Boy's bathroom sink 3 (by boiler rm)	I	OT	05/07/2022 12:02PM	<1	ppb			DR-NH	06/24/2022 06:53PM
2205-01600-050	Room 164 sink	I	OT	05/07/2022 12:09PM	10.7	ppb			DR-NH	06/24/2022 07:02PM
2205-01600-051	Room 112 Pre-K sink	I	OT	05/07/2022 12:06PM	<1	ppb			DR-NH	06/24/2022 07:04PM
2205-01600-052	Girl's bathroom sink 1 (by Pre-K)	I	OT	05/07/2022 12:07PM	<1	ppb			DR-NH	06/24/2022 07:07PM
2205-01600-053	Girl's bathroom sink 2 (by Pre-K)	I	OT	05/07/2022 12:07PM	<1	ppb			DR-NH	06/24/2022 07:10PM
2205-01600-054	Adult bathroom (by Pre-K)	I	OT	05/07/2022 12:07PM	1.3	ppb			DR-NH	06/24/2022 07:22PM
2205-01600-055	Boy's bathroom sink 1 (by Pre-K)	I	OT	05/07/2022 12:08PM	<1	ppb			DR-NH	06/24/2022 07:25PM
2205-01600-056	Boy's bathroom sink 2 (by Pre-K)	I	OT	05/07/2022 12:08PM	<1	ppb			DR-NH	06/24/2022 07:28PM
2205-01600-057	Boy's bathroom sink 3 (by Pre-K)	I	OT	05/07/2022 12:08PM	<1	ppb			DR-NH	06/24/2022 07:31PM

Rebecca L. Labranche
 Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 06/28/2022
CLIENT NAME: Poland Community School

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

CLIENT ADDRESS: 1250 Maine Street
 Poland, ME 04274

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 05/10/2022 03:25PM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 22° CELSIUS
CLIENT JOB #: 361

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2205-01600-058	Room 159 sink	I	OT	05/07/2022 12:09PM	<1	ppb			DR-NH	06/24/2022 07:34PM
2205-01600-059	Hose bib in courtyard	I	OT	05/07/2022 12:39PM	11.2	ppb			DR-NH	06/24/2022 07:37PM
2205-01600-060	Hose bib by dumpster	I	OT	05/07/2022 12:38PM	26.2	ppb			DR-NH	06/24/2022 07:46PM
2205-01600-061	Hose bib by main entrance	I	OT	05/07/2022 12:41PM	46.1	ppb			DR-NH	06/24/2022 07:48PM
2205-01600-062	Hose bib by oil tank	I	OT	05/07/2022 12:42PM	4.4	ppb			DR-NH	06/24/2022 07:57PM
2205-01600-063	Room 207 sink	I	OT	05/07/2022 12:17PM	7.4	ppb			DR-NH	06/24/2022 08:00PM
2205-01600-064	Room 206 sink	I	OT	05/07/2022 12:17PM	6.9	ppb			DR-NH	06/24/2022 08:03PM
2205-01600-065	Room 205 sink	I	OT	05/07/2022 12:17PM	36.6	ppb			DR-NH	06/24/2022 08:06PM
2205-01600-066	Room 204 sink	I	OT	05/07/2022 12:18PM	11.8	ppb			DR-NH	06/24/2022 08:09PM
2205-01600-067	Room 202 sink	I	OT	05/07/2022 12:19PM	34.1	ppb			DR-NH	06/24/2022 08:12PM
2205-01600-068	Room 209 sink	I	OT	05/07/2022 12:16PM	28.9	ppb			DR-NH	06/24/2022 08:15PM
2205-01600-069	Boy's room sink 1 (2nd floor)	I	OT	05/07/2022 12:15PM	3.2	ppb			DR-NH	06/24/2022 08:18PM
2205-01600-070	Boy's room sink 2 (2nd floor)	I	OT	05/07/2022 12:15PM	2.4	ppb			DR-NH	06/24/2022 08:54PM
2205-01600-071	Girl's room sink 2 (2nd floor)	I	OT	05/07/2022 12:14PM	<1	ppb			DR-NH	06/24/2022 08:57PM
2205-01600-072	Girl's room sink 1 (2nd floor)	I	OT	05/07/2022 12:14PM	<1	ppb			DR-NH	06/24/2022 09:00PM

Rebecca L. Labranche
 Laboratory Director